Certificate No: LR2623337TA
Issue Date: 05/06/2026
Expiry Date: 26/07/2030

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Mersen France SB SAS**
Address	15, Rue Jacques de Vaucanson, Saint Bonnet De Mure, 69720, France
Place of Production	FUSETECH kft 38 Guba Sándor utca, Kaposvár, 7400, Hungary
Type	Switches - Ac
Description	Fuse switch-disconnector TYPE LINOCUR D02 05861.063040 - 1 pole 05862.063040 - 2 poles 05863.063040 - 3 poles 05863.063140 - 3 poles + neutral
Trade Name	LINOCUR D02
Application	Marine application for use in environmental categories ENV1 and ENV2 as defined in LR Type Approval System, Test Specification Number 1- July 2024.
Specified Standard	IEC 60947-3:2020 + AMD1:2025 Ed 4.1 DIN VDE 0638: 09.81 + A1: 2005.09 + Corrigendum 1:2018.12

Downloaded Copy

Pawan Borate

Specialist Electrical & Control to Lloyd's Register Marine and Offshore India LLP
A member of the Lloyd's Register group

Units 1702-1704, 17th Floor (Level-13), Building Q2, Aurum Q Parc; Gen 4/1 TTC, Thane-Belapur Road, Ghansoli, Navi Mumbai, 400710, India

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2623337TA
Issue Date: 05/06/2026
Expiry Date: 26/07/2030

Type Approval Certificate

Ratings

Utilization Category	Rated Voltage Ue	Rated Current Ie	Thermal Current Ith
AC 22 B	255/ 440	2 - 63	63
AC 23 B	255/ 440	2 - 35	35
AC 23 B	255/ 400	2 - 50	50
DC 22 A	65	2 - 63	63
AC 22	230/ 400	2 - 63	63

Other Conditions

Type Approval does not eliminate the need (as required by LR Rules) the requirements for further review or for the product to be further inspected and/ or surveyed to be installed in ships classed or intended to be classed with LR.

If the specified standards are amended during the validity of this certificate, the product is to be reapproved prior to it being supplied to vessels to which the amended standards apply.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Marine and Offshore India LLP of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR2023662TA-02

The Design Appraisal Document TSO-25-039110-E-01 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

Units 1702-1704, 17th Floor (Level-13), Building Q2, Aurum Q Parc; Gen 4/1 TTC, Thane-Belapur Road, Ghansoli, Navi Mumbai, 400710, India

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.