Certificate No: LR25193426TA
Issue Date: 01/09/2025
Expiry Date: 31/08/2030

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**GESTRA AG**
Address	Muenchener Str. 77, Bremen, 28215, Germany
Type	Level Indicators
Description	Water Level Transmitter
Trade Name	NRGT26-2s
Application	Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2 and ENV3 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1 – March 2019.
Specified Standard	Manufacturer specifications IACS unified requirements E10 (Rev.9 Aug 2023)
Ratings	Power supply: 24V DC Safety Extra Low Voltage (SELV) Output: 4 to 20mA Working range: 32 bar in case of 238°C
Additional Tests	Degree of protection: IP 65

Downloaded Copy

Thorsten Wolff

Electrical & Control - Senior Specialist to
Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR25193426TA
Issue Date: 01/09/2025
Expiry Date: 31/08/2030

Type Approval Certificate

Other Conditions

For Water Level Transmitter NRGT26-2s with a protective tube length ≥1000 mm, an annular support must be attached around the protective tube at a distance of 900 mm from the start of the protective tube. For protective tube length ≥1500 mm, an additional annular support must be provided at a distance of 100 mm from the end of the protective tube.
The support must not be fix connected to the-protective tube.

A certified 24V DC power supply unit with Safety Extra Low Voltage (SELV) which is separated from switched loads is to be used.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR2011813TA

The Design Appraisal Document TSO-25-030105/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.