Certificate No: LR26312726TA
Issue Date: 02/07/2026
Expiry Date: 01/07/2031

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Bticino Spa**
Address	Viale L. Borri, 231, Varese, 21100, Italy
Type	BUSDUCT
Description	Busbars systems: MS Mini Sbarra and XCP High Power busbar
Trade Name	Busbars MS, XCP
Application	Marine use in environmental category ENV1 and ENV2, as detailed in Lloyd's Register Test Specification No.1, July 2024
Specified Standard	IEC 61439-6:2012
Ratings	MS: 63A to 160A XCP: 630A to 6300A
Additional Tests	Valid for XCP only: -Seismic qualification tests according with IEC60068-2-57:2013; IEC60068-2-6:2009; IEEE 693:2018 -Fire Resistant in accordance with IEC 60331-1 -Sprinkler test in accordance with manufacturer specification

Downloaded Copy

Ilir Batalli

Electrical & Control - Senior Specialist to
Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR26312726TA
Issue Date: 02/07/2026
Expiry Date: 01/07/2031

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document LR26312726DA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.