Certificate No: LR26375328TA
Issue Date: 11/03/2026
Expiry Date: 10/03/2031

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**TRICAB (AUSTRALIA) PTY LTD**
Address	33 Prohasky St, Port Melbourne, 3207, Australia
Place of Production	TRICAB (AUSTRALIA) PTY LTD 33 Prohasky St, Port Melbourne, 3207, Australia
Place of Production	TriCab (USA) Inc. 15 Coppage Drive, Worcester, Massachusetts, 01603, United States
Type	Control Cables
Description	Fire retardant and/or flame retardant, flexible (1) , low smoke, halogen free, HEPR crosslinked insulated, SHF-1/SHF-2 oversheathed, single and multicore power and control cables with or without braid or optional Plexus metal tape/ armour MKA (SHF-1) Flame retardant, without braid/armour PJA (SHF-1) Flame retardant, with braid or optional Plexus metal PJC (SHF-2) tape /armour and drain-wire (2) RRA (SHF-1) Fire resistant (3), without braid or optional Plexus metal RRC (SHF-2) tape /armour HTA (SHF-1) Fire resistant (3), with braid or optional Plexus metal tape HTC (SHF-2) /armour and drain-wire (2) BHA (SHF-1) Fire resistant (3), with braid or optional Plexus metal tape BHC (SHF-2) /armour and drain-wire (2) (1) Plain or tinned annealed copper conductor (2) Braid: Galvanised steel wire, plain / tinned copper wire or Bronzed wire or optional Plexus metal tape/armour

Downloaded Copy

Ping Yuan Qi

Electrical & Control - Lead Specialist to
Lloyd's Register Singapore Pte Ltd
A member of the Lloyd's Register group

9 North Buona Vista Drive, #02-01, Metropolis
Tower 1, 138588, Singapore

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Type Approval Certificate

Armour: Steel wire
Drain-wire: Available if required under the braid
(3) Flame barrier: Halogen free glass mica tape

Trade Name	0.6/1kV Power and Control Cables
Application	Marine, offshore and industrial installations
Specified Standard	IEC 60092-350, IEC 60092-360, IEC 60092-376, IEC 60228, IEC 60332-1-2, IEC 60332-3-22, IEC 60331-1&2, IEC 60754-1&2, IEC 61034-2, IEC 60811-504:2012, IEC 60811-505:2012, IEC 60811-506:2012
Ratings	0.6/1kV
Additional Tests	IEC 60811-504, Bending Tests at Low Temperature, - 50°C IEC 60811-505, Elongation at Low Temperature, - 50°C IEC 60811-506, Impact Test at Low Temperature, - 50°C

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Singapore Pte Ltd of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR21122232TA-01

The Design Appraisal Document LR26375328TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

9 North Buona Vista Drive, #02-01, Metropolis
Tower 1, 138588, Singapore

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.