Certificate No: LR21191050TA
Issue Date: 10/08/2021
Expiry Date: 25/05/2026

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**ABB SpA - Electrification Business Distribution Solutions**
Address	Via Friuli, 4, Dalmine, (BG), Italy, 24044, Italy
Type	Contactors
Description	Medium Voltage Vacuum Contactor V7/P V7/C V7/UN V7/W V12/P
Trade Name	V-Contact V7 & V12
Application	Marine and mobile Offshore units for use in environmental categories ENV1, ENV2 and ENV3 as defined in Lloyd's Register Test Specification No. 1: 2020.
Specified Standard	IEC 62271-106: 2021

Ratings

TYPE:	V7	V12
Voltage [kV]:	7.2	12
Utilization Category:	AC-4	AC-4
Frequency [Hz]:	50 / 60	50/60
Current [A]:	400	400
Breaking Capacity [kA]:	4	4
Coupled Fuses [A]:	63 - 315	63 - 200

Downloaded Copy

Paolo Scialla

Principal Electrotechnical Specialist to
Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR21191050TA
Issue Date: 10/08/2021
Expiry Date: 25/05/2026

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 00/00118(E5) and 01/00119(E4)

The Design Appraisal Document LR21191050DA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.