Certificate No: LR26425496TA
Issue Date: 03/09/2026
Expiry Date: 29/04/2031

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Danfoss A/S**
Address	Nordborgvej 81, Nordborg, 6430, Denmark
Place of Production	Danfoss Poland Sp. z o.o. ul. Chrzanowska 5, Grodzisk Mazowiecki, 05-825, Poland
Type	Switches - Temperature
Description	The RT thermostats are single-pole double-throw (SPDT) temperature-controlled switches with cylindrical remote sensor
Trade Name	RT 106, RT 107, RT 123
Application	Marine,Offshore and Industrial applications for use in environmental categories ENV1, ENV2 and ENV3, as defined in Lloyd's Register Type Approval System, Test Specification Number 1 – July 2024.
Specified Standard	EN 60947-1: 2024 EN 60947-4-1: 2023 EN 60947-5-1: 2024 IACS E10 Rev. 10 / 2024
Ratings	Ambient temperature range: -50 °C to +70 °C

Downloaded Copy

CHETAN WAGH

Senior Specialist Electrical & Control to Lloyd's Register Marine and Offshore India LLP

Units 1702-1704, 17th Floor (Level-13), Building Q2, Aurum Q Parc; Gen 4/1 TTC, Thane-Belapur Road, Ghansoli, Navi Mumbai, 400710, India

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Type Approval Certificate

Operating temperature range:
RT 106: +20 °C to +90 °C
RT 107: +70 °C to +150 °C
RT 123: +150 °C to +250 °C

Contact load at 400 VAC:
AC-1: 10 A
AC-3: 4 A
AC-15: 3 A

Contact load at 220 VDC:
DC-13: 12 W

Additional Tests Enclosure test IP 66

Other Conditions Type Approval does not eliminate the need (as required by LR Rules) the requirements for further review or for the product to be further inspected and/ or surveyed to be installed in ships classed or intended to be classed with.

If the specified standards are amended during the validity of this certificate, the product is to be reapproved prior to it being supplied to vessels to which the amended standards apply.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Marine and Offshore India LLP of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR21366305TA

The Design Appraisal Document TSO/26-055918-E-01 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

Units 1702-1704, 17th Floor (Level-13), Building Q2, Aurum Q Parc; Gen 4/1 TTC, Thane-Belapur Road, Ghansoli, Navi Mumbai, 400710, India

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.