Certificate No: LR2605892TA
Issue Date: 23/04/2026
Expiry Date: 25/08/2029

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer **ABB AG – STOTZ-KONTAKT**

Address Eppelheimer Str. 82, Heidelberg, 69123, Germany

Type Contactors

Description Low voltage contactors

Trade Name B6, B7

Application Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2 and ENV3 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1 – 1996.

Specified Standard
EN IEC 60947-4-1:2019/AC:2020-05
EN 60947-5-1:2017/AC:2020-05
EN 60947-1: 2007/A1: 2011/A2:2014

Ratings

Type	Utilisation Category	Operational Voltage Ue	Operational Current Ie	Thermal Current Ith
B6	AC3	240V	8A	20A
	AC3	440V	8A	20A
	AC3	500V	6.5A	12A

Downloaded Copy

Thorsten Wolff
Electrical & Control - Senior Specialist to Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2605892TA
Issue Date: 23/04/2026
Expiry Date: 25/08/2029

Type Approval Certificate

B7	AC3	240V	11A	20A
	AC3	440V	11A	20A
	AC3	500V	9A	12A

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR2002182TA

The Design Appraisal Document TSO-25-047552/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.