Certificate No: LR22513677TA
Issue Date: 01/08/2022
Expiry Date: 31/07/2027

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Kwant Controls BV**
Address	Voltastraat 3, SNEEK, 8606 JW, Netherlands
Type	Control Systems
Description	Relay Box containing the telegraph system; Containing Printed Circuit Board
Trade Name	98033
Application	Suitable as part of ships'communication/control system, in environment categories ENV1, ENV2 & ENV3, as defined in LR Test Specification No. 1, 2021
Specified Standard	Manufacturer's Specification

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 17/30017

The Design Appraisal Document PRJ11100389659-3 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

Henri Reekers

Snr Electrical Surveyor to Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.