Certificate No: LR2002537TA
Issue Date: 19/05/2020
Expiry Date: 17/06/2022

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Eaton Industries (Austria) GmbH**
Address	Eugenia 1, Schrems, 3943, Austria
Place of Production	EATON ELECTRO PRODUCTIE SRL Independentei Street No 8, SARBI, Maramures, 437157, Romania
Type	Circuit Breakers (Non Env Tested)
Description	Residual current operated circuit-breaker with integral overcurrent protection FRBmM-1p+N, FRBmM-2p, FRBmM-3p FRBm4-1p+N, FRBm4-3p, FRBm4-3p+N FRBm6-1p+N, FRBm6-2p, FRBm6-3p, FRBm6-3p+N Option: Circuit breaker can be supplemented with auxiliary contact block of type: Z-AHK, Z-ASA, Z-NHK, Z-USA, ZP-ASA, ZP-IHK, ZP-NHK, ZP-WHK
Trade Name	FRBmM, FRBm4, FRBm6
Application	Marine, offshore and industrial applications for intended use in installations

Downloaded Copy

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA
A member of the Lloyd's Register Group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2002537TA
Issue Date: 19/05/2020
Expiry Date: 17/06/2022

Type Approval Certificate

Specified Standard	EN61009-1:2012+A1:2014+A2:2014+A11:2015+A12:2016 EN61009-2-1:1994+A11:1998 EN61543:1995+A11:2003+A12:2005+A2:2006
Ratings	Rated voltage: 240 VAC, 415 VAC Rated current: 2 – 40 A Rated fault current: 10 mA, 30 mA, 100 mA, 300 mA Number of poles: 1p+N, 2p, 3p, 3p+N Tripping characteristic: B, C, D

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. HTS/ETS 39708-20/MK/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.