Certificate No: LR25364098TA
Issue Date: 05/09/2024
Expiry Date: 04/09/2029

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Honeywell Co., Ltd.**
Address	5F SangAm IT Tower, 434, World Cup buk-ro, Mapo-gu, Seoul, 03922, South Korea
Type	Gas analyser units
Description	Sensepoint XCD Flammable Gas Detector Sensepoint XCD Flammable- IR Gas Detector Sensepoint XCD Remote Flammable Detector Sensepoint XCD Oxygen Gas Detector Sensepoint XCD Toxic
Trade Name	Sensepoint XCD
Application	Gas Detection for use in hazardous and non-hazardous areas in Environmental categories ENV5 as defined in Lloyd’s Register Test Specification No. 1: 2024
Specified Standard	IEC 60092-504: 2016 EN 60079-0:2018 EN 60079-1:2014 EN 60079-31:2014 EN 50104:2010 EN 45544-1:2015, EN 45544-3:2015 EN 60529: 2013 EN 60079-29-1:2007

Downloaded Copy

Gyung-Hwan Lee

Electrical & Control - Lead Specialist to
Lloyd's Register Asia
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR25364098TA
Issue Date: 05/09/2024
Expiry Date: 04/09/2029

Type Approval Certificate

Ratings

Hazardous Areas Components (ATEX, IECEx)

Transmitter:-
Ex d IIC T6(Ta- 40° C to + 65° C) Gb, T5(Ta- 40° C to + 75° C)Gb
Ex tb IIIC T85°C (Ta- 40° C to + 65° C) Db, T100°C (Ta- 40° C to + 75° C) Db, IP66

Gas Sensor Head:-
Ex d IIC T6(Ta - 40° C to + 65° C) Gb, T4(Ta - 40° C to + 75° C) Gb
Ex tb IIIC T85°C (Ta - 40° C to + 65° C) Db, T135 °C (Ta - 40° C to + 75° C)Db, IP6X

Other Conditions

Type Approval does not eliminate the need (as required by LR Rules) the requirements for further review or for the product to be further inspected and/ or surveyed to be installed in ships classed or intended to be classed with LR.
If the specified standards are amended during the validity of this certificate, the product is to be reapproved prior to it being supplied to vessels to which the amended standards apply.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Asia of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 14/00052(E2)

The Design Appraisal Document LR25364098TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.