Certificate No: LR2003484TA
Issue Date: 04/05/2020
Expiry Date: 03/05/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**UNIVERSAL CABLE (M) BHD**
Address	No. 33, Jalan Tiran, Kangkar Tebrau, Johor Bahru, Johor, 81100, Malaysia
Type	Power Cables
Description	0.6/1(1.2)kV, EPR Insulated Fire Resistant or Flame Retardant, Low Smoke and Halogen Free Power Cables
Trade Name	RFOU : EPR insulated, LSOH bedding, Tinned copper wire braided, SHF2 outer sheathed Flame retardant Power cable BFOU : Mica tape layer, EPR insulated
Application	Fixed wiring on marine and offshore installations
Specified Standard	IEC60228, IEC60092-350, IEC60092-353, IEC60092-360,IEC60502, IEC60332-1, IEC60332-3-22 Cat.A, IEC60331-1, IEC60331-21, IEC60754,IEC61034 Manufacturer's specification : LR-E-RFOU-1kV-R LR-E-BFOU-1kV-R LR-E-BFCI-1kV-R
Ratings	0.6/1(1.2)kV
Additional Tests	NEK606 for RFOU, BFOU type

Downloaded Copy

Hui Luan Tan

Senior Specialist - Marine to Lloyd's Register Singapore Pte Ltd
A member of the Lloyd's Register group

1 Fusionopolis Place, #09-11 Galaxis, 138522, Singapore

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2003484TA
Issue Date: 04/05/2020
Expiry Date: 03/05/2025

Type Approval Certificate

ASTM D 2863 for Minimum Oxygen Concentration

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Singapore Pte Ltd of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. LR2003484TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

1 Fusionopolis Place, #09-11 Galaxis, 138522,
Singapore

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.