Certificate No: LR2002023TA
Issue Date: 29/01/2020
Expiry Date: 26/01/2023

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Finder S.p.A.**
Address	Via Drubiaglio 14, Almese To, 10040, Italy
Type	Relays - Magnetic, With Time Delay
Description	Series 62 Power Relays Type: 62.22 62.32 62.82 62.23 62.33 62.83
Application	Marine, Offshore and Industrial use in environmental categories ENV1, ENV2, ENV3 as defined in Lloyd's Register Test Specification No. 1: 2019.
Specified Standard	EN 61810-1:2015
Ratings	2 and 3 pole relays Rated Voltage: 250 Vac Rated Current: 16 A
Other Conditions	The present Certificate is intended as the amendment of Type Approval Certificate number 03/00016 (E3)

Downloaded Copy

Andrei Petrov

Surveyor to Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, UK

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2002023TA
Issue Date: 29/01/2020
Expiry Date: 26/01/2023

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. LR2002023DA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, UK

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.