Certificate No: LR2004632TA
Issue Date: 02/07/2020
Expiry Date: 01/07/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Zhejiang Jindun Pressure Vessel Co.,Ltd**
Address	Xiao Yue Industrial Area, Shaoxing, 312367, China
Place of Production	Zhejiang Jindun Pressure Vessel Co.,Ltd Xiao Yue Industrial Area, Shaoxing, 312367, China
Type	Cylinder
Description	CO2 & N2 Cylinder ISO9809 - (67.5, 80, 82.5L) – 166.7 For storage of compressed, liquefied gases exposed to ambient temperatures between -20˚C and +65˚C CO2 & N2 Cylinder tube body Material: 37Mn Water capacity: 67.5L, 80L & 82.5L Working pressure: 166.7 bar Test pressure: 250 bar Heat treatment: Quenched and tempered Shape of base: Concave Filling Medium: Carbon Dioxide (CO2) and Nitrogen (N2) Filling ratio: 0.66kg/L (for Carbon Dioxide CO2)CO2 & N2 Cylinder tube body Material: 37Mn Water capa
Trade Name	JD

Downloaded Copy

Jing Guan

Specialist to Lloyd's Register Classification Society (China) Co Ltd
A member of the Lloyd's Register Group

19th Floor, 550 Yan An dong Road, Shanghai, Huangpu District, China

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2004632TA
Issue Date: 02/07/2020
Expiry Date: 01/07/2025

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Classification Society (China) Co Ltd of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

19th Floor, 550 Yan An dong Road, Shanghai,
Huangpu District, China

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.