Certificate No: LR26176320TA
Issue Date: 04/03/2026
Expiry Date: 03/03/2031

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Utsunomiya Electric Mfg. Co., Ltd.**
Address	3-5-1, Higashi-Shinagawa, Shinagawa-ku, Tokyo, 140-0002, Japan
Place of Production	Utsunomiya Electric Mfg. Co., Ltd. 8358 Oba, Fujisawa, Kanagawa, 251-0861, Japan
Type	Fuses
Description	Non-Renewable Cartridge Type Low-voltage Fuse-links
Trade Name	UC0
Application	Marine and offshore applications for protection of distribution circuits.
Specified Standard	JIS C 8352-2015
Ratings	Rated Voltage : AC500V/DC250V Rated Current of Fuse Element : 1, 2, 3,5, 10, 15, 20, 25, 30A RatedBreaking Capacity : 50kA at AC500V, 20kA at DC250V

Downloaded Copy

Sachie Fujii

Electrical & Control - Senior Specialist to
Lloyd's Register Group Limited
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR26176320TA
Issue Date: 04/03/2026
Expiry Date: 03/03/2031

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Group Limited of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR21206703TA

The Design Appraisal Document LR26176320TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.