Certificate No: LR2520350TA
Issue Date: 17/12/2024
Expiry Date: 16/12/2029

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Tratos Cavi Spa**
Address	Via Stadio 2, Pieve S. Stefano Ar, 52036, Italy
Type	Cables Control, Telecommunication And Instrumentation
Description	Individually or individually and collectively screened, unarmoured and flame retardant telecommunication and instrumentation cables Conductor: Annealed plain copper Insulation: HF-XLPE compound Shield: Aluminium / polyester tape Outer sheath: Thermoplastic compound SHF1
Trade Name	TRATOSMARINE UIS & UICS - 60V &250V
Application	Marine and Offshore fixed wiring
Specified Standard	IEC 60092-350:2020 IEC 60092-351:2014 IEC 60092-376:2003 IEC 60332-1-2:2006 IEC 60332-3-22:2009 CAT.A IEC 61034-2:2005

Downloaded Copy

Maurizio Crucil

Electrical & Control Technical Manager - South Europe to Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2520350TA
Issue Date: 17/12/2024
Expiry Date: 16/12/2029

Type Approval Certificate

Ratings

TRATOSMARINE UIS &UICS - 60V

Number of pairs:	Cross sectional area:
2, 4, 7, 10, 14, 19 ,24, 30	0.5mm^2

TRATOSMARINE UIS &UICS - 250V

Number of pairs:	Cross sectional area:
2, 4, 7, 10, 14, 19 ,24, 30	0.75, 1.0, 1.5mm^2

Number of triples:	Cross sectional area:
4, 7, 10, 14, 19	1.0, 1.5mm^2

Other Conditions Operational limitations: Maximum conductor temperature: 90°C

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR2003589TA-01

The Design Appraisal Document LR2520350DA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.