Certificate No: LR2001918TA
Issue Date: 18/02/2020
Expiry Date: 17/02/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	**Dubai Cable Co. (Pvt) Ltd.**
Address	P.O. Box 11529, Jebel Ali, Dubai, United Arab Emirates
Place of Production	Dubai Cable Company (Private) Limited P. O. Box. 9171, Ducab M1, Musaffah, Abu Dhabi, United Arab Emirates
Place of Production	Dubai Cable Company (Private) Limited P. O. Box. 9171, Ducab M2, Musaffah, Abu Dhabi, United Arab Emirates
Place of Production	Dubai Cable Co. (Pvt) Ltd. PO Box 9171, Ducab M1, Mussafah, Abu Dhabi, United Arab Emirates
Type	Low Voltage Cables
Description	Cu/MGT/XLPE/LSZH/Braid/LSZH-SHF1 (0.6/1kV) and Cu/XLPE/LSZH/Braid/ LSZH-SHF1 (0.6/1kV) (Fire resistant & non-fire resistant versions) Conductor: Plain or tinned copper, Class 2 or 5 Insulation: XLPE / HF-90 Braid: Plain or tinned Cu/Cu alloy or galvanised steel Outer Sheath: LSZH – SHF1 Cu/MGT/XLPE/LSZH-SHF1 (0.6/1kV) and Cu/XLPE/LSZH-SHF1 (0.6/1kV) (Fire resistant & non-fire resistant versions) Conductor: Plain or tinned copper, Class 2 or 5 Insulation: XLPE / HF-90 Outer Sheath: LSZH-SHF1

Downloaded Copy

Andrei Petrov

Surveyor to Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, UK

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2001918TA
Issue Date: 18/02/2020
Expiry Date: 17/02/2025

Type Approval Certificate

Trade Name	Marinebicc
Type	Instrumentation Cables
Description	Cu/MGT/XLPE/LSZH/Braid/LSZH-SHF1 (150/250V) and Cu/XLPE/LSZH/Braid/ LSZH-SHF1 (150/250V) (Fire resistant & non fire resistant versions) (Overall screen and individual/overall screen versions) Conductor:Plain or tinned copper, class 2 or 5 Insulation:XLPE / HF-90 Braid:Plain or tinned Cu/Cu alloy or galvanised steel Outer Sheath:LSZH – SHF1 Cu/MGT/XLPE/LSZH-SHF1 (150/250V) and Cu/XLPE/ LSZH-SHF1 (150/250V) (Fire resistant & non fire resistant versions) (Overall screen and individual overall screen
Trade Name	Marinebicc
Type	Flame Retardant Switchboard Cables
Description	Cu/HF90 (0.6/1kV) Conductor: Plain or tinned copper, class 2 or 5 Insulation: HF90
Trade Name	Marinebicc
Application	Fixed marine installations
Specified Standard	IEC 60092-353: 2016 IEC 61034- 1 & 2: 2013 IEC 60754-1 & 2: 2011 IEC60332-1-2: 2015

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, UK

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Certificate No: LR2001918TA
Issue Date: 18/02/2020
Expiry Date: 17/02/2025

Type Approval Certificate

IEC60332-3-22: 2009 CAT A
IEC 60092-376: 2017
IEC60331-1 & 2: 2009
IEC60331-21: 1999

Ratings See Appendix

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. LR2001918TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Downloaded Copy

71 Fenchurch Street, London, EC3M 4BS, UK

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.